SIEMENS

Data sheet

6GK5204-0BA00-2BA3

SCALANCE X204IRT, managed IE IRT switch, 4x 10/100 Mbit/s RJ45 ports, Error signaling contact with set pushbutton, redundant power supply, PROFINET IO device, network management, Redundancy Manager integrated, incl. electron. manual on CD-ROM, C-plug optional

Product type designation	SCALANCE X204IRT
Transfer rate	
Transfer rate	10 Mbit/s, 100 Mbit/s
Interfaces / for communication / Integrated	
Number of electrical connections	
 for network components or terminal equipment 	4
Interfaces / other	
Number of electrical connections	
 for signaling contact 	1
• for power supply	1
 for redundant voltage supply 	1
Type of electrical connection	
 for signaling contact 	2-pole terminal block
• for power supply	4-pole terminal block
design of the removable storage	
• C-PLUG	Yes
Signal inputs/outputs	

Operating voltage / of the signaling contacts	-	
at DC / Rated value	24 V	
Operating current / of the signaling contacts	0.1 A	
• at DC / maximum	0.1 A	
Supply voltage, current consumption, power loss		
Type of voltage / of the supply voltage	DC	
Supply voltage		
• external	24 V	
• external / minimum	18 V	
 external / maximum 	32 V	
Product component / fusing at power supply input	Yes	
Fuse protection type / at input for supply voltage	0.6 A / 60 V	
Consumed current / maximum	0.2 A	
Power loss [W]		
• at DC / at 24 V	4.8 W	
Ambient conditions		
Ambient temperature		
 during operation 	-40 +70 °C	
 during storage 	-40 +70 °C	
 during transport 	-40 +70 °C	
Relative humidity		
• at 25 °C / without condensation / during	95 %	
operation / maximum		
Protection class IP	IP30	
Design	compact	
Width	60 mm	
Height	125 mm	
Depth	124 mm	
Net weight	0.78 kg	
Mounting type		
• 35 mm DIN rail mounting	Yes	
wall mounting	Yes	
 S7-300 rail mounting 	Yes	
• S7-1500 rail mounting	No	
Product features, product functions, product components / general		
Cascading in the case of a redundant ring / at	50	
reconfiguration time of <\~0.3\~s		
Cascading in cases of star topology	any (depending only on signal propagation time)	

Product functions / management, configuration, engineering	
Product function	
• CLI	Yes

	Vee
web-based management	Yes
MIB support	Yes
• TRAPs via email	Yes
Configuration with STEP 7	Yes
Port mirroring	No
 multiport mirroring 	No
 with IRT / PROFINET IO switch 	Yes
PROFINET IO diagnosis	Yes
PROFINET conformity class	С
Product function / switch-managed	Yes
Protocol / is supported	
● Telnet	Yes
• HTTP	Yes
• HTTPS	Yes
• TFTP	Yes
• FTP	Yes
• BOOTP	No
• DCP	Yes
• LLDP	Yes
• SNMP v1	Yes
• SNMP v2	Yes
• SNMP v3	Yes
Identification & maintenance function	
 I&M0 - device-specific information 	Yes
 I&M1 – higher-level designation/location 	Yes
designation	
Product functions / Diagnostics	
Product functions / Diagnostics	
Port diagnostics	Yes
Statistics Packet Size	Yes
Statistics packet type	Yes
Error statistics	Yes
Product functions / DHCP	
Product function	
DHCP client	Yes
Product functions / redundancy	
Product function	
 Ring redundancy 	Yes
 High Speed Redundancy Protocol (HRP) 	Yes
 high speed redundancy protocol (HRP) with 	Yes
redundancy manager	

 high speed redundancy protocol (HRP) with standby redundancy 	Yes
Protocol / is supported / Media Redundancy Protocol (MRP)	Yes
Product function	
 media redundancy protocol (MRP) with redundancy manager 	Yes
 Parallel Redundancy Protocol (PRP)/operation in the PRP-network 	Yes
 Parallel Redundancy Protocol (PRP)/Redundant Network Access (RNA) 	No
Passive listening	Yes
Product functions / Security	
Protocol / is supported	
• SSH	Yes
Product functions / time	
Product function	
 SICLOCK support 	Yes
Protocol / is supported	
• NTP	No
• SNTP	Yes
• 0111	100
Standards, specifications, approvals	
Standards, specifications, approvals Standard	
	FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4
Standard	
Standard ● for FM	GP. IIC, T4 EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA
Standard • for FM • for hazardous zone	GP. IIC, T4 EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X
Standard • for FM • for hazardous zone • for safety / from CSA and UL	GP. IIC, T4 EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X UL 60950-1, CSA C22.2 No. 60950-1 ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 /
Standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL	GP. IIC, T4 EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X UL 60950-1, CSA C22.2 No. 60950-1 ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4
Standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference	GP. IIC, T4 EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X UL 60950-1, CSA C22.2 No. 60950-1 ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 EN 61000-6-4:2001 (Class A)
Standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity	GP. IIC, T4 EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X UL 60950-1, CSA C22.2 No. 60950-1 ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 EN 61000-6-4:2001 (Class A)
Standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity Standards, specifications, approvals / CE	GP. IIC, T4 EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X UL 60950-1, CSA C22.2 No. 60950-1 ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 EN 61000-6-4:2001 (Class A) EN 61000-6-4:2001
Standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking	GP. IIC, T4 EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X UL 60950-1, CSA C22.2 No. 60950-1 ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 EN 61000-6-4:2001 (Class A) EN 61000-6-4:2001
Standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity <u>Standards, specifications, approvals / CE</u> Certificate of suitability / CE marking <u>Standards, specifications, approvals / other</u>	GP. IIC, T4 EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X UL 60950-1, CSA C22.2 No. 60950-1 ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 EN 61000-6-4:2001 (Class A) EN 61000-6-4:2001
Standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking Standards, specifications, approvals / other Certificate of suitability	GP. IIC, T4 EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X UL 60950-1, CSA C22.2 No. 60950-1 ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 EN 61000-6-4:2001 (Class A) EN 61000-6-4:2001 Yes
Standard • for FM • for hazardous zone • for safety / from CSA and UL • for hazardous zone / from CSA and UL • for hazardous zone / from CSA and UL • for emitted interference • for interference immunity Standards, specifications, approvals / CE Certificate of suitability / CE marking Standards, specifications, approvals / other Certificate of suitability • C-Tick • Railway application in accordance with EN	GP. IIC, T4 EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X UL 60950-1, CSA C22.2 No. 60950-1 ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 EN 61000-6-4:2001 (Class A) EN 61000-6-4:2001 Yes

Standards, specifications, approvals / marine classi	ification
Marine classification association	
 American Bureau of Shipping Europe Ltd. 	Yes
(ABS)	
• Bureau Veritas (BV)	Yes
 Det Norske Veritas (DNV) 	No
Germanische Lloyd (GL)	No
• DNV GL	Yes
 Lloyds Register of Shipping (LRS) 	Yes
 Nippon Kaiji Kyokai (NK) 	Yes
 Polski Rejestr Statkow (PRS) 	Yes
 Royal Institution of Naval Architects (RINA) 	Yes
Standards, specifications, approvals / Product confe	ormity
MTBF	80.58 y
accessories	
Product extension / optional / C-PLUG	Yes
Further information / Internet-Links	
Internet-Link	
to website: Selector SIMATIC NET SELECTION TOOL	http://www.siemens.com/snst
• to website: Industrial communication	http://www.siemens.com/simatic-net
• to website: Industry Mall	https://mall.industry.siemens.com
 to website: Information and Download Center 	http://www.siemens.com/industry/infocenter
 to website: Image database 	http://automation.siemens.com/bilddb
 to website: CAx Download Manager 	http://www.siemens.com/cax
 to website: Industry Online Support 	https://support.industry.siemens.com
Security information	
Security information	Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third- party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified: