SIEMENS

Data sheet

6GK5208-0HA10-2AA6



SCALANCE X208PRO, managed IE switch, 8x 10/100 Mbit/s M12 ports, IP65/67, LED diagnostics, error signaling contact, Redundant power supply, PROFINET IO device, network management, can be operated in redundant ring, dust caps, incl. electronic manual on CD-ROM, C-plug optional

Product type designation	SCALANCE X208PRO
Transfer rate	
Transfer rate	10 Mbit/s, 100 Mbit/s
Interfaces / for communication / Integrated	
Number of electrical connections	
• for network components or terminal equipment	8
Number of 10/100 Mbit/s M12-ports (D-coded) /	8
Integrated	
Interfaces / other	
Number of electrical connections	
• for signaling contact	1
• for power supply	1
 for redundant voltage supply 	1
Type of electrical connection	
• for signaling contact	5-pin M12 socket (b-coded)
for power supply	4-pin M12 interface (A-coded)
design of the removable storage	
• C-PLUG	Yes

Signal inputs/outputs	
Operating voltage / of the signaling contacts	
• at DC / Rated value	24 V
Operating current / of the signaling contacts	
• at DC / maximum	0.1 A

Supply voltage, current consumption, power loss	
Type of voltage / of the supply voltage	DC
Supply voltage	
• external	24 V
external / minimum	18 V
external / maximum	32 V
Product component / fusing at power supply input	Yes
Fuse protection type / at input for supply voltage	0.6 A / 60 V
Consumed current / maximum	0.185 A
Power loss [W]	
• at DC / at 24 V	4.4 W

Ambient conditions	
Ambient temperature	
during operation	-40 +70 °C
during storage	-40 +70 °C
during transport	-40 +70 °C
Relative humidity	
 at 25 °C / without condensation / during operation / maximum 	95 %
Protection class IP	IP65/67
Design	compact
Width	90 mm
Height	125 mm
Depth	124 mm
Net weight	1 kg
Mounting type	
 35 mm DIN rail mounting 	Yes
wall mounting	Yes
• S7-300 rail mounting	Yes
• S7-1500 rail mounting	No

Product features, product functions, product components / general	
Cascading in the case of a redundant ring / at	100
reconfiguration time of <\~0.3\~s	
Cascading in cases of star topology	any (depending only on signal propagation time)

Product functions / management, configuration, engineering		
_	Product function	

• CLI	Yes
web-based management	Yes
 MIB support 	Yes
• TRAPs via email	Yes
Configuration with STEP 7	Yes
Port mirroring	Yes
 multiport mirroring 	No
with IRT / PROFINET IO switch	No
 PROFINET IO diagnosis 	Yes
PROFINET conformity class	В
Product function / switch-managed	Yes
Protocol / is supported	
• Telnet	Yes
• HTTP	Yes
• HTTPS	Yes
• TFTP	Yes
• FTP	Yes
• BOOTP	No
• DCP	Yes
• LLDP	Yes
• SNMP v1	Yes
• SNMP v2	Yes
• SNMP v3	Yes
Identification & maintenance function	
 I&M0 - device-specific information 	Yes
 I&M1 – higher-level designation/location 	Yes
designation	
Product functions / Diagnostics	
Product function	
Port diagnostics	Yes
Statistics Packet Size	Yes
Statistics packet type	Yes
• Error statistics	Yes
D. J. J. G. W. C. A. A. D. L. C.	
Product functions / DHCP Product function	
DHCP client	Yes
Product functions / redundancy	
Product function	Voc
Ring redundancy	Yes
 High Speed Redundancy Protocol (HRP) 	Yes

 high speed redundancy protocol (HRP) with 	Yes
redundancy manager	
 high speed redundancy protocol (HRP) with standby redundancy 	No
Protocol / is supported / Media Redundancy Protocol (MRP)	Yes
Product function	
 media redundancy protocol (MRP) with redundancy manager 	Yes
Passive listening	Yes
Product functions / Security	
Protocol / is supported	
• SSH	Yes
Product functions / time	
Product function	
 SICLOCK support 	Yes
Protocol / is supported	
• NTP	No
• SNTP	Yes
Standards, specifications, approvals	
Standard	
• for FM	FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4
• for hazardous zone	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X
for safety / from CSA and UL	UL 60950-1, CSA C22.2 No. 60950-1
• for hazardous zone / from CSA and UL	ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4
• for emitted interference	EN 61000-6-4 (Class A)
• for interference immunity	EN 61000-6-2
Standards, specifications, approvals / CE	
Certificate of suitability / CE marking	Yes
Standards, specifications, approvals / other	
Certificate of suitability	EN 61000-6-2, EN 61000-6-4
• C-Tick	Yes
 Railway application in accordance with EN 50155 	No
 Railway application in accordance with EN 50124-1 	No
• KC approval	Yes
Standards, specifications, approvals / Product conf	ormity.

MTBF 83 y Product extension / optional / C-PLUG Yes Further information / Internet-Links Internet-Link • to website: Selector SIMATIC NET http://www.siemens.com/snst **SELECTION TOOL** http://www.siemens.com/simatic-net • to website: Industrial communication https://mall.industry.siemens.com • to website: Industry Mall http://www.siemens.com/industry/infocenter • to website: Information and Download Center http://automation.siemens.com/bilddb • to website: Image database http://www.siemens.com/cax • to website: CAx Download Manager https://support.industry.siemens.com • to website: Industry Online Support

Security information

Security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Thirdparty products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified:

11/11/2019